



October 13, 2011

CERTIFICATE OF EFFICIENCY
NORASYSTEM[®] PRODUCTS

We undersigned, LABORATOIRES PHODE S.A.S., certify that:

The efficiency of NORASYSTEM[®] has been measured by an external laboratory (during a PhD thesis carried out at the Rennes Chemistry National School).

The gas level reductions have been obtained in certain laboratory conditions, on a test bench, and are reported below :

- Ammonia : 91.4%
- Nitrogen compounds like Trimethylamine : 90%
- Sulphur compounds like Hydrogen sulphide : 54%
- Sulphur compounds like Methyl mercaptan : 44%
- Volatile fatty acids / Carboxylic acid like Butyric acid: 80%

These values are indications, the efficiency of NORASYSTEM[®] products depending of various parameters, such as:

- the olfactory pollutants concentration,
- the air flow to treat,
- the fogging system which will be employed,
- etc.

For use by authorised persons only

Visa of quality manager
Nelly GALLOY